

GRANITE POWER GENERATION CORPORATION

TEL: (613) 382-2118
FAX: (613) 382-3385

P.O. BOX 548, 5 KING STREET EAST
GANANOQUE, ONTARIO
K7G 2V1

21 August, 2002

Xtreme Seal
PO Box 30023
Kingston ON K7K7B5

To Whom It May Concern:


Last year December 3rd, 2001 Xtreme Seal Waterproofing and Roofing provided Granite Power Corporation with samples of High Build liquid rubber, Spray Grade liquid rubber and Non-Skid Resurfacer for zebra muscle adhesion testing.

The samples were placed in a power station reservoir, which is thick with zebra muscle growth. After eight months of exposure to the zebra muscle environment, there is little or no zebra muscle adhesion on the three product samples provided.

On the concrete block sample, several good-sized zebra muscles had adhered where no liquid rubber had been applied on the block. All samples were examined and returned to the same location for continued testing.

John Russell from Xtreme Seal was present during the examination and took pictures of the samples documenting our observations.

Yours truly,



Murray Hall
Superintendent Operations